

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2021/SZ/109

Dated: 11/02/2021

FIRE SAFETY CERTIFICATE

Certified that the Holy World School, Arjun Park, Ishwar Colony, New Delhi-110043, comprised of ground floor plus three upper floors, owned/occupied by Holy World School was issued FSC by this department vide letter F6/DFS/MS/2017/SZ/1579 dated 07/11/2017. The School building was re-inspected by the officer concerned of this department on 26/01/2021 in the presence of Smt. Archana and found that the School building have deemed complied the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Educational" for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 11/02/2021 at New Delhi.



(Sunil Chawdhary)
Dy. Chief Fire Officer

Copy to:-

1. The Principal,
Holy World School,
Arjun Park, Ishwar Colony, New Delhi-110043
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.


MANAGER
HOLY WORLD SCHOOL
Sr. Sec. Recognized & Affiliated to CBSE
Near Nangli Metro Station, Pillar No. 69,
New Delhi-110043


PRINCIPAL
HOLY WORLD SCHOOL
Sr. Sec. Recognized & Affiliated to CBSE
Near Nangli Metro Station, Pillar No. 69,
New Delhi-110043