



DELHI JAL BOARD  
( GOVT. OF N.C.T. DELHI )  
QUALITY CONTROL LABORATORY,  
WATER TREATMENT PLANT NANGLOI, DELHI-110041



Water sample collected from " Holy World School" Arjun Park, Ishwar Colony, New Delhi -110043 vide challan No- 50 Dated- 15.05.2023.

S. No	Parameter	Units	Limit		S1
			Acceptable	Permissible	
<b>PHYSICAL EXAMINATION</b>					
1.	Date of collection	-----	--	--	30.05.2023
2.	Date of Analysis	-----	--	--	02.06.2023
3.	Colour	Hazen	5.0	15	Clear
4.	Odour	-----	No. Objectionable		No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	1.0
6.	PH value	-----	6.5	8.5	7.0
7.	Electrical Conductivity	µmho	--	--	175
8.	Total dissolved solids	mg/l	500	2000	113.7
<b>CHEMICAL EXAMINATION</b>					
9.	P <sup>th</sup> Alkalinity	mg/l	--	--	NIL
10.	Total Alkalinity	mg/l	200	600	40
11.	Total Hardness	mg/l	200	600	56
12.	Calcium Hardness	mg/l	--	--	32
13.	Magnesium Hardness	mg/l	--	--	24
14.	Calcium as Ca	mg/l	75	200	12.8
15.	Magnesium as Mg	mg/l	30	100	5.76
16.	Ammonia as N	mg/l	0.5	N.R.	NIL
17.	Nitrite as N	mg/l	---	--	NIL
18.	Nitrate as NO <sub>3</sub>	mg/l	45	N.R.	1.2
19.	Sulphate	mg/l	200	400	12
20.	Chloride	mg/l	250	1000	16
21.	Dissolved Iron	mg/l	0.3	N.R.	0.02
22.	Fluoride	mg/l	1	1.5	NIL
23.	Cyanide	mg/l	0.05	N.R.	ND
24.	Residual Chlorine	mg/l	0.20	1.0	NIL
<b>BACTERIOLOGICAL EXAMINATION</b>					
25.	Coli-form per 100 ml at 37°C	MPN	0		0


REMARKS : As per tested parameters sample -S1 can be use for drinking purpose.

Chemist

ACWA


Asstt. Chief Water Analyst  
DELHI JAL BOARD  
Govt. of N.C.T. Delhi  
Quality Control Laboratory  
Water Works Nangloi, Delhi-41





# MUNICIPAL CORPORATION OF DELHI

OFFICE OF THE DY. HEALTH OFFICER : NAJAFGARH ZONE  
ROOM NO.408, 4<sup>TH</sup> FLOOR, ZONAL BUILDING, DHANSA STAND,  
NAJAFGARH, NEW DELHI 110043



No.DHO/NGZ/2023/ 942

Dated 01/05/2023

1. Name of the School **HOLY WORLD SCHOOL**
2. School Address **ARJUN PARK, ISHWAR COLONY, NEW DELHI-110043**
3. No. of Shift ONE Timing 8:00 AM TO 01:30 PM
4. No. of Students: Boys =698 Girls 458 Total =1156
5. No. of Staffs: Male 08 Female 50 Total = 58

### Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient SUFFICIENT
2. The Classrooms are Well Lighted/ ill lighted WELL LIGHTED
3. The Classrooms are Well Ventilated/ ill ventilated WELL VETILATED
4. The Classrooms are kept / Not kept Neat & Clean: NEAT AND CLEAN
5. The Classrooms/Building requires/ do not required Whitewash etc. NOT REQUIRED
6. The Drinking Water is Wholesome/ not wholesome WHOLESOME
7. The Latrine arrangement is Sanitary/ insanitary SANITARY FROM HEALTH POINT OF VIEW.


### No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is SUFFICIENT
2. One latrine for 40 male student is required so total is SUFFICIENT
3. Separate Toilet arrangement for staff present: Yes/No YES SEPARATE EXISTS FOR STAFF.
4. The Overall facilities: Good/ Adequate/Inadequate V.GOOD FROM HEALTH POINT OF VIEW AND

VALID UP TO ONE YEAR FROM ISSUANCE DATE.

If Building Department or any other Govt. agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/revoked without any further intimation in this regard.

(Remark: Certificate is valid for one year)

  
Deputy Health Officer  
Najafgarh Zone  
Deputy Health Officer  
Najafgarh Zone, MCD