



# AMCO SPECTRO AND MATERIAL TESTING LAB LLP

Tel. : +91-9266-69-9990  
+91-9891-57-3910

Lab : A-71, Group Wazirpur Industrial Area, New Delhi-110052  
Web : www.testinglabindia.com, Email : amcotestinglab@gmail.com



## TEST REPORT

FF : 7.8.1.1

Issued To: M/s. Holy World School  
Arjun Park, Ishwar Colony  
New Delhi- 110043  
India.

W.O No: AMCO/49/05  
Report No: 25010405  
Date of Issue: 10-01-2025  
Date of Receipt: 04-01-2025  
Party Ref. No: PV & Verbal Dated 04-01-2025  
Order Confirmation Date: 04-01-2025

## SAMPLE PARTICULARS

1. Sample Packaging: In Plastic bottle.
2. Sample Quantity: Approx 1 litre.
3. Lot No/Batch No: NA
4. Date of Manufacturing: NA
5. Date of Expiry: NA
6. Sample Description: One sample described by party as Water for Drinking purpose, was received for following tests only.

PAGE 1 OF 1

## TESTS RESULTS

S.NO	TESTS	TEST METHODS	RESULTS	REQUIREMENTS (IS:10500-2012)	CONFORMITY
1	Odour	IS:3025 (PART 5)-18 RA: 2022	Agreeable	Agreeable	YES
2	Taste	IS:3025 (PART 7)-17 RA: 2022	Agreeable	Agreeable	YES
3	Colour, Hazen Units	IS:3025 (PART 4)-21	<5	A. 5 max as acceptable limit B. 15 max as Permissible Limit	YES
4	pH Value	IS:3025 (PART 11)-22	7.9	6.5 to 8.5	YES
5	Total Dissolved Solids, mg/l	IS:3025 (PART 16)-23	63	A. 500 max as acceptable limit B. 2000 max as permissible limit	YES
6	Turbidity, NTU	IS:3025 (PART 10)-23	<1	A. 1 max as acceptable limit B. 5 max as permissible limit	YES
7	Chloride as Cl, mg/l	IS:3025 (PART 32)-88 RA: 2019	23.3	A. 250 max as acceptable limit B. 1000 max as permissible limit	YES
8	Calcium as Ca, mg/l	IS:3025 (PART 21)-09 RA: 2023	1.96	A. 75 max as acceptable limit B. 200 max as permissible limit	YES
9	Magnesium as Mg, mg/l	IS:3025 (PART 46)-23	2.35	A. 30 max as acceptable limit B. 100 max as permissible limit	YES
10	Total Hardness as CaCO <sub>3</sub> , mg/l	IS: 3025 (Part 21)-09 RA: 2023	14.7	A. 200 max as acceptable limit B. 600 max as permissible limit	YES
11	Flouride as F, mg/l	IS:3025 (PART 60)-23	<0.1	A. 1.0 max as acceptable limit B. 1.5 max as permissible limit	YES
12	Iron as Fe, mg/l	IS:3025 (PART 53)-03 RA: 2023	<0.1	A. 0.3 max as acceptable limit	YES
<b>BACTERIOLOGICAL TESTS</b>					
13	Coliform	IS: 15185-2016	Absent	Shall not be detectable in any 100ml sample	YES
14	E. Coli	IS: 15185-2016	Absent	Shall not be detectable in any 100ml sample	YES

Remark: The sample confirms to IS: 10500-2012 w.r.t to above tests only.

\*\*\*\*

Authorised Signatory  
LAB


Civil / Mechanical / Chemical / NDT TESTING

1. The results listed refer only to samples and applicable parameters. 2. Endorsement of product is neither inferred nor implied. 3. Total liability of our lab is limited to the invoiced amount. 4. Samples will be destroyed after 15 days from the date of test certificate unless specified otherwise. 5. Perishable samples will be destroyed in 2 to 7 days as applicable. 6. The Report shall not be reproduced except in full without written approval of Laboratory. 7. Report refers to the sample submitted to us and not drawn by Amco Spectro and Material Testing Lab LLP unless mentioned otherwise. 8. Retesting Charges will be applicable if results are reproducible. 9. Duplicate copy will be issued on chargeable basis. 10. In case of any dispute, the jurisdiction shall be New Delhi Courts.





MUNICIPAL CORPORATION OF DELHI  
OFFICE OF DEPUTY HEALTH OFFICER  
NAJAFGARH ZONE



No: DHO/NGZ/MCD/2025/D- 1563

Dated ..16/01/2025

1. Name of the School: - **HOLY WORLD SCHOOL**
2. SCHOOL ADDRESS - Arjun Park, Ishwar Colony, New Delhi-110043.
3. NO. OF SHIFT ONE TIMING 08:00 AM TO 01:30 PM
4. NO. OF STUDENTS: BOYS - 1044 GIRLS - 733 TOTAL = 1777
5. NO. OF STAFFS: MALE - 04 FEMALE - 68 TOTAL = 72

Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient **SUFFICIENT**
2. The Classrooms are Well Lighted/ill lighted **WELL LIGHTED**
3. The Classrooms are Well Ventilated/ill ventilated **WELL VENTILATED**
4. The Classrooms are kept / Not kept Neat & Clean: **NEAT AND CLEAN**
5. The Building requires/does not required Whitewash etc. **NOT REQUIRED**
6. The Drinking Water is Wholesome/Not wholesome **WHOLESOME**
7. The Latrine arrangement is Sanitary/Insanitary **SANITARY FROM HEALTH POINT OF VIEW.**

No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is **SUFFICIENT**
2. One latrine for 40 male student is required so total is **SUFFICIENT**
3. Separate Toilet arrangement for staff present: Yes/No **YES SEPARATE EXISTS FOR STAFF.**
4. The Overall facilities: Good/ Adequate/Inadequate **GOOD FROM HEALTH POINT OF VIEW.**

*If building Department or any other govt. agency takes actions against u/a construction or any dispute, then the Health Certificate will be stand cancelled /revoked without any further intimation in this regard*

*A Ket*

Deputy Health Officer  
Deputy Najafgarh Zone  
Municipal Corporation Of Delhi  
Health Deptt., Najafgarh Zone

(Remarks: This Certificate is valid for one year from the date of issue and this has no bearing on any unauthorized construction)